



JOE ASSOCIATES

CONSULTING ARCHITECTS ENGINEERS & VALUERS
BERACHAH TOWER, CHIRAYANKUZHI JN., KANJIRACODE P.O., PIN : 629 155.

Ph : (O) 04651 - 271080, Mob : 9443607580, Email : plsonjoe@yahoo.com.

Website : www.joeassociates.com

Er. J. PISON JOE, B.Sc., B.E., M.I.E., C.Eng (I), F.I.V.

Regd. Engineer Grade - I | S. B. I. Panel Valuer | Approved Valuer | Karnataka Bank Panel Valuer | Indian Bank Panel Valuer | Govt. Regd. Valuer | Bank of Maharashtra Panel Valuer |
Dist. Panel Eng. Class-IA | P.N.B. Panel Valuer | Chartered Engineer | Regd. Structural Eng. Grade-II | Federal Bank Panel Valuer | TIIC Panel Valuer | Indian Overseas Bank Panel Valuer |

STATEMENT ACCOMPANYING FORM - A

H01/S/23

- | | |
|---|---|
| 1. Door Number of Building | : 5 - 41 - 2 |
| 2. Location (street no. ward no.) Name of place i.e.
Corp./Municipality/ Panchayat Union/ Township | : HOLY TRINITY INTERNATIONAL SCHOOL
Melpalai, Edaicode P.O., K.K. Dist.
Tamil Nadu. |
| 3. Year of Construction | : 2015 |
| 4. Approximate cost of construction as per current rates | : ₹ 1,50,00,000 |
| 5. Purpose for which the building is being used or
proposed to be used. | : Class Rooms, Office & Library |
| 6. Purpose for which the building has hitherto been used | : Class Rooms, Office & Library |
| 7. Details of construction of the building (particulars of the
foundation soil, specification of the various parts under): | |
| i. Foundation | : R.C.C. Column Footing. |
| ii. Basement | : R.R.M. in Cement Mortar. |
| iii. Superstructure | : R.C.C. Framed Structure & C.B. in C. M. |
| iv. Floor | : Partly Granite & Marbonite |
| v. Roof | : R.C.C. |
| 8. Period for which license is required | : 01.06.2022 to 31.05.2025 (Three Years) |
| 9. Number of persons to be accommodated | : 680 Nos. |

Date: 15.07.2023

Govt. Registered Engineer

Er. J. PISON JOE, B.Sc., B.E., M.I.E., C.Eng (I), F.I.V.

Dist. Panel Engineer, Class - 1A

JOE ASSOCIATES

CHIRAYANKUZHI, KANJIRACODE, Ph: 04651-271080

Certified that no addition or alteration has been made to the existing building or portion of the building for which this application has been made. I undertake to obtain fresh license, in case addition or alteration is made to the existing building or portion of the building. I also undertake to obtain fresh license, if the purpose for which the license was granted for the use of the building originally is changed or altered subsequently.

Date:

Signature of the owner of the building

FORM – B

Form of certificate of Structural Soundness under sub-section 4 of the Madras Public Buildings (Licensing) Act 1965, (Madras Act 13 of 1965) referred to in Rule of the Madras Public Building (Licensing) Rules 1966.

I certify that I have inspected the buildings mentioned in the statement and furnish below its technical features:

1. FOUNDATION

- | | | | |
|------|---|---|------------------------|
| i. | Depth below Ground Level | : | 2.10 m |
| ii. | Nature of soil met with at foundation level | : | Hard Gravely soil |
| iii. | Pressure of foundation | : | 31.80 t/m ² |
| iv. | Probable S.B. Capacity of the strata met with at foundation | : | 45 t/m ² |

2. SUPERSTRUCTURE

- | | | | |
|-----|--|---|---|
| i. | Maximum stress in the most critical section of masonry and Concrete. | : | Does not arise since it is a Framed Structure |
| ii. | Nature of masonry and Concrete and its safe permissible stress | : | ---- |

The structural soundness of the building has been verified by me with reference to ISI loading standard 875 (Latest version) and other relevant INDIAN STANDARDS CODE OF PRACTICE and I declare the building is structurally sound to be used as Public Building for the purpose noted in the statement. A license may be granted for the period from **01.06.2022 to 31.05.2025** (Three Years)



Date: 15.07.2023

Govt. Registered Engineer

P.J. PISON JOE, B.Sc., B.E., M.I.E., C.Eng(I), F.I.V.
Dist. Panel Engineer, Class - 1A
JOE ASSOCIATES
CHIRAYANKUZZHI, KANJIRACODE, Ph: 04651-271080

FORM - C

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the Building Door No., Street and Place.	Age of the building	No. of stories	Short description	Certified purpose the building stability	Certified period for the building stability	No. of persons to be accommodated	Remarks
D. No: 5 - 41 - 2 HOLY TRINITY INTERNATIONAL SCHOOL, Melpalai, Edaicode P.O. K.K. Dist. Tamil Nadu,	8 Years	C. F., G. F., F. F. & S. F. Four Stories	R.C.C. Framed Structure, R.C.C. roof, Country wood doors & Windows	Office, Library & Class Rooms	01.06.2022 to 31.05.2025 (Three Years)	680 Nos.	---



Date: 15.07.2023

Govt. Registered Engineer

P. JOE, B.Sc., B.E., M.I.E., C.Eng(I), F.I.V.
Dist. Panel Engineer, Class - 1A
JOE ASSOCIATES
CHIRAYANKUZZHI, KANJIRACODE, Ph: 04651-271080

From

District Collector,
Kanniyakumari District,
at Nagercoil.

To

Thiru.J.Pison Joe,
Joe Associates,
15-26 A5,
Berachar Tower,
Chirayan Kuzhi,
Kanjiracode Post,
Kanniyakumari.

E1/4378/2017 dated:13.02.2017

Sir,

Sub : Up gradation of the name of private practicing Engineer class IA in Kanniyakumari District - Informed - Regarding.

Ref : 1. Your Application dated:
2. Engineer - in - Chief, WRD and Chief Engineer (General), PWO, Chepaik. Chennai -5, Letter No.AEE/T1/AE/27655/2015,dated:27.01.2017.

It is hereby informed that your name has been up gradation in the panel of private practicing Engineer Under Class I to Class IA (one A) category (Buildings, the cost of which exceeds Rs.50 lakhs) in Kanniyakumari District as per Engineer - in - Chief (Buildings) Chennai Reign. Chief Engineer (General) Public Work Department, Chennai in the letter read in the reference 2nd cited.

Sd/-S.Natarajan,
For Collector,
Additional Personal Assistant
(Land) to Collector,
Nagercoil.

// True copy // by order//

Head Assistant (E)